



Declaration of Conformity

For the following equipme	ent:					
Product Name: DALI-PW	M Signal Co	nverter				
Model Designation: DAP-	04					
is herewith confirmed to were applied:	comply with	the requirements se	et out in th	e Council [Directive, th	he following standards
RoHS Directive (201 Low Voltage Directive	,	FUN :				
EN61347-1:2008+A1+A2 EN61347-2-11:2001	•	TUV certificate	No:R50	271983		
Electromagnetic Com EMI (Electro-Magnetic In Conducted emission / R	nterference adiated emi)	•			
Harmonic current	EN61000-3-2:2006+A1:2009+A2:2009					
Voltage flicker	EN61000-3-3: 2008					
EMS (Electro-Magnetic	Susceptibil	ity)				
EN61547: 2009						
ESD air	EN61000-4-2:2009		Level 3	8KV		
ESD contact	EN61000-4-2:2009		Level 2	4KV		
RF field susceptibility	EN61000-4-3:2006+A1:2008+A2:2010		Level 2	3V/m		
EFT bursts	EN61000-4-4:2012			Level 2	1KV/5KH	łz
Surge susceptibility	EN61000-4-5:2006			Level 2	1KV/Line	-Line
Surge susceptibility	EN61000-4-5:2006			Level 3	2KV/Line	-Earth
Conducted susceptibility	EN61000-	4-6:2009		Level 2	3V	
Magnetic field immunity	EN61000-	4-8:2010		Level 2	3A/m	
Voltage dip, interruption	EN61000-4-	-11:2004 >95% dip 0.5	periods 3	0% dip 25 pe	riods >95%	6 interruptions 250 periods
Note: Component power supply wiinstallation, the final equipme Tests above are only to be p For guidance on how to perfe	nt manufactur erformed with	ers must re-qualify EM0 LEDs.	C Directive of	on the comple	ete installatio	on again.
This Declaration is effective	from serial nu	mber RB6xxxxxxx				
Person responsible for m	arking this d	eclaration:				
MEAN WELL Enterprises (Manufacturer Name)	Co., Ltd.					
No.28, Wuquan 3rd Rd., (Manufacturer Address)	Wugu Dist.,	New Taipei City 248	, Taiwan			
,	nation Contor :		Ted Char	na/Director S	ales Dont	M 100
Johnny Huang/Manager, Certification Center (Name / Position)		(Signature)	Ted Cheng/Director, Sales Dept. : (Signature)			
Taiwan (Place)		Apr. 20th, 2016 (Date)				J