



Declaration of Conformity

For the following equipmer	nt:	·	
Product Name: Switching Power Supply			
Model Designation: DPU-3200-xz (x=24,48; z=NC,PM,CAN) DBU-3200-xy (x=24,48; y=NC,CAN)			
is herewith confirmed to c were applied :	comply with the requirements	set out in the Council [Directive, the following standards
RoHS Directive (2011	/65/EU)		
Low Voltage Directive (2014/35/EU):			
EN62368-1:2014+A11	11 TUV certificate No: R50400447		
Electromagnetic Compatibility Directive (2014/30 EMI (Electro-Magnetic Interference) Conducted emission EN55032:2015 Radiated emission EN55032:2015		O/EU): Class B Class A	
EMS (Electro-Magnetic S	susceptibility)		
EN55024:2010+A1:2015	EN61000-6-2:2005		
ESD air	EN61000-4-2:2009	Level 3	8KV
ESD contact	EN61000-4-2:2009	Level 2	4KV
RF field susceptibility	EN61000-4-3:2006+A1:2008	3+A2:2010 Level 3	10V/m
EFT bursts	EN61000-4-4:2012	Level 3	2KV/5KHz
Surge susceptibility	EN61000-4-5:2014	Level 3	2KV/Line-Line
Conducted susceptibility	EN61000-4-6:2014	Level 3	10V
Magnetic field immunity	EN61000-4-8:2010	Level 4	30A/m
Voltage dip, interruption	EN61000-4-11:2004 >95% dip (0.5 periods 30% dip 25 pe	riods >95% interruptions 250 periods
Note: The power supply is considered as a component that will be operated in combination with final equipment. Since EMC performance will be affected by the complete installation, the final equipment manufacturers must re-qualify EMC Directive on the complete installation again. For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File).			
This Declaration is effective from serial number EB8xxxxxxx			
Person responsible for marking this declaration :			
MEAN WELL Enterprises ((Manufacturer Name) No.28, Wuquan 3rd Rd., W	Co., Ltd. /ugu Dist., New Taipei City 248	s, Taiwan	
(Manufacturer Address)			
Johnny Huang/Manager, Certification Center: (Name / Position) Alex Tsai/Director, Marketing Department: (Name / Position) (Signature)			
Taiwan	Feb .12th, 2018		

(Date)

(Place)