



## **Declaration of Conformity**

| Deciaration of Comornity  |                               |                 |             |                                    |
|---|-------------------------------|-----------------|-------------|------------------------------------|
| For the following equipment:  |                               |                 |             |                                    |
| Product Name: Din-Rail Switching Power Supply   |                               |                 |             |                                    |
| Model Designation: DRC-100x (x=A or B)  |                               |                 |             |                                    |
| is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied :  |                               |                 |             |                                    |
| RoHS Directive (2011/65/EU)   |                               |                 |             |                                    |
| Low Voltage Directive (2014/35/EU):   |                               |                 |             |                                    |
| EN60950-1:2006+A11+A1+A12+A2 TUV certificate No : R50300458   |                               |                 |             |                                    |
| Electromagnetic Compatibility Directive (2014/30/EU):  EMI (Electro-Magnetic Interference)  Conducted emission / Radiated emission  EN55032:2015  Class B   |                               |                 |             |                                    |
| Harmonic current  | EN61000-3-2:2014              |                 |             |                                    |
| Voltage flicker   | EN61000-3-3:2013              |                 |             |                                    |
| EMS (Electro-Magnetic Susceptibility)   |                               |                 |             |                                    |
| EN55024:2010+A1:2015  |                               |                 |             |                                    |
| ESD air   | EN61000-4-2:2009              | Le              | evel 3      | 8KV                                |
| ESD contact   | EN61000-4-2:2009              | Le              | evel 2      | 4KV                                |
| RF field susceptibility   | EN61000-4-3:2006+A1:2008+     | -A2:2010 Le     | evel 2      | 3V/m                               |
| EFT bursts  | EN61000-4-4:2012              | Le              | evel 2      | 1KV/5KHz                           |
| Surge susceptibility  | EN61000-4-5:2014              | Le              | evel 3      | 1KV/Line-Line                      |
| Surge susceptibility  | EN61000-4-5:2014              | Le              | evel 3      | 2KV/Line-Earth                     |
| Conducted susceptibility  | EN61000-4-6:2014              | Le              | evel 3      | 3V                                 |
| Magnetic field immunity   | EN61000-4-8:2010              | Le              | evel 4      | 3A/m                               |
| Voltage dip, interruption   | EN61000-4-11:2004 >95% dip 0. | 5 periods 30% c | dip 25 peri | ods >95% interruptions 250 periods |
| Note:  The power supply is considered as a component that will be operated in combination with final equipment. Since EMC performance will be affected by the complete system, the final equipment manufacturers must re-qualify EMC Directive on the complete system again.  For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File). |                               |                 |             |                                    |
| This Declaration is effective from serial number EB7xxxxxxx   |                               |                 |             |                                    |
| Person responsible for marking this declaration:  |                               |                 |             |                                    |
| MEAN WELL Enterprises Co., Ltd. (Manufacturer Name) No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 248, Taiwan  |                               |                 |             |                                    |
| (Manufacturer Address)  |                               |                 |             | MINO                               |
| Johnny Huang/Manager, Certification Center:  (Name / Position)  Ted Cheng/Director, Sales Dept.:  (Signature)  Ted Cheng/Director, Sales Dept.:  (Signature)  |                               |                 |             |                                    |
| Taiwan  | Mar. 5th, 2017                |                 |             |                                    |

(Date)

(Place)