

# CE

## **Declaration of conformity**

For the following equipment :

Product Name: Switching Power Supply

Model Designation: EPP-120S-y (y=12,15,24,27,48)

is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied :

### RoHS Directive (2011/65/EU) 、(EU)2015/863

### Low Voltage Directive (2014/35/EU) :

EN 62368-1:2014+A11

TUV certificate No : R 50431670

#### Electromagnetic Compatibility Directive (2014/30/EU) :

EMI (Electro-Magnetic Interference)						
Conducted emission	EN55032:2015	Class B				
Radiated emission	EN55032:2015	Class A(for Class ${\rm I\hspace{-1.4mm}I}$ ) ; Class B(for Class ${\rm I}$ )				
Harmonic current	EN61000-3-2:2014					
Voltage flicker	EN61000-3-3:2013					

#### EMS (Electro-Magnetic Susceptibility)

EN55024:2010+A1:2015

EIN55024.2010+A1.2015			
ESD air	EN61000-4-2:2009	Level 3	8KV
ESD contact	EN61000-4-2:2009	Level 3	4KV
RF field susceptibility	EN61000-4-3:2006+A1:2008+A2:2010	Level 3	10V/m
EFT bursts	EN61000-4-4:2012	Level 3	2KV/5KHz
Surge susceptibility	EN61000-4-5:2014+A1:2017	Level 4	2KV/Line-Line
Surge susceptibility	EN61000-4-5:2014+A1:2017	Level 4	4KV/Line-Earth
Conducted susceptibility	EN61000-4-6:2014	Level 3	10V
Magnetic field immunity	EN61000-4-8:2010	Level 4	30A/m

Voltage dip, interruption EN61000-4-11:2004+A1:2017 >95% dip 0.5 periods 30% dip 25 periods >95% interruptions 250 periods

#### Note:

The power supply is considered as a component that will be operated in combination with final equipment. Since EMC performance will be affected by the complete system, the final equipment manufacturers must re-qualify EMC Directive on the complete system again.

For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File).

This Declaration is effective from serial number EB9xxxxxx

#### Person responsible for marking this declaration :

MEAN WELL Enterprises Co., Ltd.							
(Manufacturer Name)							
No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 24891, Taiwan							
(Manufacturer Address)	0		Ob				
Johnny Huang/ Manager, Certification Center : Alex Tsai/Director, Marketing Department :							
(Name / Position)	(Signature)	(Name / Position)	(Signature)				
Taiwan	Jul. 22nd, 2019						
(Place)	(Date)						

Version: 1