



Declaration of Conformity

For the following equipment :

Product Name: Switching Power Supply

Model Designation: LSP-160-XZ,LSP-160R-XZ,LSP-160-YZ (X=3.3,4.2,5;Y=12,24,36,48;Z=W,T)

is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied :

RoHS Directive (2011/65/EU) 、(EU)2015/863

Low Voltage Directive (2014/35/EU) :

EN62368-1:2014+A11

TUV certificate No : R50459267

Class B

Electromagnetic Compatibility Directive (2014/30/EU) :

EMI (Electro-Magnetic Interference)

Conducted emission / Radiated emission

	EN55052.2015		
Harmonic current	EN61000-3-2:2014		

Voltage flicker EN61000-3-3:2013

EMS (Electro-Magnetic Susceptibility)

EN55035:2017			
ESD air	EN61000-4-2:2009	Level 3	8KV
ESD contact	EN61000-4-2:2009	Level 2	4KV
RF field susceptibility	EN61000-4-3:2006+A1:2008+A2:2010	Level 3	10V/m
EFT bursts	EN61000-4-4:2012	Level 3	2KV/5KHz
Surge susceptibility	EN61000-4-5:2014+A1:2017	Level 4	2KV/Line-Line
Surge susceptibility	EN61000-4-5:2014+A1:2017	Level 4	4KV/Line-Earth
Conducted susceptibility	EN61000-4-6:2014	Level 3	10V
Magnetic field immunity	EN61000-4-8:2010	Level 4	30A/m
Voltage dip. interruption	EN61000-4-11:2004+A1:2017 >95% dip 0.5 pe	riods 30% dip	25 periods >95% interruptions 250 periods

Voltage dip, interruption EN61000-4-11:2004+A1:2017 >95% dip 0.5 periods 30% dip 25 periods >95% interruptions 250 periods Note:

A component power supply with load will be installed into final equipment which consists of an electronically shielded metal enclosure. Since EMC performance will be affected by the complete installation, the final equipment manufacturers must re-qualify EMC Directive on the complete installation again.

The EMC tests mentioned above are performed using a well defined metal plate to simulate said metal enclosure.

For guidance on how to perform these EMC tests, please refer to "EMI testing of component power supplies".(as available on <u>http://www.meanwell.com</u>)" and TDF (Technical Documentation File).

This Declaration is effective from serial number HC0xxxxxxx

Person responsible for marking this declaration :

	MEAN	WELL	Enterprises	Co	Ltd.
--	------	------	-------------	----	------

(Manufacturer Name)

No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 24891, Taiwan

(Manufacturer Address)			a
Johnny Huang/Manager, Certification Center	Olim	Alex Tsai/Director, Marketing Department :	Clos
(Name / Position)	(Signature)	(Name / Position)	(Signature)
Taiwan	Feb. 21st, 2020		
(Place)	(Date)		
(Place)	(Date)		