



Declaration of conformity

For the following equipment:
Product Name: LED Driver
Model Designation: XBG-160-x-y (x=A or AB, y=blank or C)
is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards wer applied :

RoHS Directive (2011/65/EU)

Energy-Related Products Directive (2009/125/EC)
Implementing measure COMMISSION REGULATION(EC) No 1194/2012

Low Voltage Directive (2014/35/EU):

EN 61347-1:2015 EN61347-2-13:2014/A1:2017 ENEC certificate No: 35-108253

Electromagnetic Compatibility Directive (2014/30/EU):

EMI (Electro-Magnetic Interference)

Conducted emission / Radiated emission

	EN55015:2013+A1:2015		
Harmonic current	EN61000-3-2:2014		Class C(≧50% load)
Voltage flicker	EN61000-3-3:2013		
EMS (Electro-Magnetic S	susceptibility)		
EN61547:2009			
ESD air	EN61000-4-2:2009	Level 3	8KV
ESD contact	EN61000-4-2:2009	Level 2	4KV
RF field susceptibility	EN61000-4-3:2006+A1:2008+A2:2010	Level 2	3V/m
EFT bursts	EN61000-4-4:2012	Level 2	1KV/5KHz
Surge susceptibility	EN61000-4-5:2014	Level 4	2KV/Line-Line

Note:

Component power supply will be operated with a final equipment. Since EMC performance will be affected by the complete installation, the final equipment manufacturers must re-qualify EMC Directive on the complete installation again.

EN61000-4-11:2004 30% dip 10 periods 100% interruptions 0.5 periods

Tests above are only to be performed with LEDs.

For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File).

EN61000-4-5:2014

EN61000-4-6:2014

EN61000-4-8:2010

This Declaration is effective from serial number HB9xxxxxxx

Person responsible for marking this declaration:

MEAN WELL Enterprises Co., Ltd.

(Manufacturer Name)

Surge susceptibility

Conducted susceptibility

Magnetic field immunity

Voltage dip, interruption

No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 24891, Taiwan

(Manufacturer Address)

Johnny Huang/Manager, Certification center:

(Name / Position) (Signature)

Alex Tsai/Director, Marketing Department:

Level 4

Level 2

Level 2

4KV/Line-Earth

3V

3A/m

(Name / Position)

Taiwan Apr. 17th, 2019 (Place) (Date)

Version: 0